NOTIFICATION.

DEPARTMENT OF LAW AND PARLIAMENTARY AFFAIRS.

No. LAW 186 LCR 67, Bangalore, dated 16th September 1967.

Ordered that the Indian Boiler (Fifth Amendment) Regulations, 1967 published in G. S. R. No. 1307 dated 21st August 1967 which has been published in the *Gazette of India*, Extraordinary, Part II, Section 3, sub-section (i), dated the 2nd September 1967, be republished in the *Mysore Gazette*, for general information.

By Order and in the name of the Governor of Mysore,

H. K. ANANTHASUBBA RAO,
Under Secy. to Govt.,
Department of Law and Parliamentary Affairs.

111

GOVERNMENT OF INDIA.

NOTIFICATION

New Delhi, the 21st August 1967.

G. S. R. 1307.—In exercise of the powers conferred by Section 28 of the Indian Boilers Act, 1923 (5 of 1923), the Central Boilers Boards hereby makes the following Regulations further to amend the Indian Boiler Regulations, 1950, the same having been previously published as required by sub-section (1) of section 31 of the said Act, namely :—

1. These Regulations may be called the Indian Boiler (Fifth Amendment) Regulations, 1967.

2. In the Indian Boiler Regulations, 1950 for Regulation 255, the following Regulation shall be substituted, namely :—

"255. *Position of the Tube holes.*—Tuble holes in welded seams should be avoided. Where they are unavoidable they may be machined through welded seams after these seams have been radiographed and stress relieved. The efficiency of the ligamend in the direction of weld shall be multiplied by a weld factor not exceeding 0.95 except where the distance from the edge of the Tube hole to the edge of the weld is greater than 13 mm. (1/2 in.). The edge of the weld shall be considered to be the edge of the weld groove as machined in the plate prior to welding."

[No. BL-9 (30)/65-EEI.]

P. J. MENON, Secy.